

**WASTEWATER SYSTEM AND POTABLE WATER SUPPLY  
 INNOVATIVE AND ALTERNATIVE (I/A) TECHNOLOGY  
 GENERAL USE APPROVAL PERMIT**

**LAWS/REGULATIONS INVOLVED**

10 V.S.A. Chapter 64, Potable Water Supply and Wastewater System Permit  
 Wastewater System and Potable Water Supply Rules, Effective November 06, 2023

<b>Permittee:</b>	Infiltrator Water Technologies 4 Business Park Road, PO Box 768 Old Saybrook, CT 06475 800-221-4436 www.infiltratorwater.com	<b>Permit Number: 2010-01-R8</b> <b>Date Issued: 05/01/2024</b> <b>Date Expires: 05/01/2026</b>
-------------------	--	---

This permit is for the following gravel-less pipe distribution I/A technology models:

<b>Product Name</b>	<b>Model Number(s)</b>	<b>Design Flow (gpd)</b>
<b>Arc Series Chamber</b>	Arc 18	2.18 ft <sup>2</sup> per linear ft 10.9 ft <sup>2</sup> per unit See Manual
<b>Arc Series Chamber</b>	Arc 24	3.18 ft <sup>2</sup> per linear ft 15.9 ft <sup>2</sup> per unit See Manual
<b>Arc Series Chamber</b>	Arc 36	4.54 ft <sup>2</sup> per linear ft 22.7 ft <sup>2</sup> per unit See Manual
<b>Arc Series Chamber</b>	Arc 36HC	4.86 ft <sup>2</sup> per linear ft 24.3 ft <sup>2</sup> per unit See Manual
<b>Arc Series Chamber</b>	Arc 36LP	4.88 ft <sup>2</sup> per linear ft 24.4 ft <sup>2</sup> per unit See Separate Sizing Chart
<b>BioDiffuser Series Chamber</b>	Bio Diffuser 1620	4.86 ft <sup>2</sup> per linear ft 30.1 ft <sup>2</sup> per unit See Separate Sizing Chart
<b>Side Port Coupler</b>	Arc 18 SPC	1.7 ft <sup>2</sup> per unit See Manual
<b>Side Port Coupler</b>	Arc 24 SPC	2.3 ft <sup>2</sup> per unit See Manual
<b>Side Port Coupler</b>	Arc 36 SPC	3.55 ft <sup>2</sup> per unit See Manual
<b>Side Port Coupler</b>	Arc 36HC SPC	4.45 ft <sup>2</sup> per unit See Manual

The technologies listed in this permit are used to disperse low-strength effluent as part of the discharge to a soil-based wastewater disposal system. The technologies, consisting of subsurface, gravel-less pipe distribution systems, are hereby approved under the requirements of the regulations named above subject to the following conditions.

**1. GENERAL**

- 1.1 The technologies listed in this permit may be used as part of a soil-based wastewater system permitted under the Rules provided the conditions of this permit are met.



- 1.2 Failure by the Permittee to comply with these conditions is grounds for the Secretary to revoke or not renew the Approval Permit.
- 1.3 The approval shall expire on **May 1, 2026**. Applications for renewal of this Approval Permit shall be submitted to the Division by March 1, 2026, to avoid a lapse in approval. The renewal request shall be submitted on a form prepared by the Secretary and shall include: a description of any changes to the equipment, technical specifications and drawings, installation requirements, and operation and maintenance manuals.
- 1.4 No changes shall be made to the approved technology without prior review and approval by the Secretary.
- 1.5 This Approval Permit is based on the design, operation, and maintenance manuals submitted by the Permittee to the Secretary. Misrepresentation in the application material is grounds for the Secretary to revoke this permit.
- 1.6 If the Rules are revised during the term of this Approval Permit, this permit shall be revised as needed to conform to the revisions.
- 1.7 Site-specific permission for the use of this technology is required in the form of a Wastewater System and Potable Water Supply Permit (WW Permit).
- 1.8 This permit is not a representation or guarantee of the effectiveness, efficiency, or operation of the approved technology.
- 1.9 This General Use Approval Permit is limited to treating septic tank effluent that is characterized as low strength according to §1-805(b) of the Rules.
- 1.10 This approval is based on information submitted by the Permittee indicating that the technology will effectively distribute and treat the effluent.
- 1.11 Each Vermont landowner in interest shall be shown a copy of the Wastewater System and Potable Water Supply Innovative and Alternative System General Use Approval Permit, the Operation and Maintenance manuals, and projected maintenance costs prior to the installation of any permitted unit.
- 1.12 All components of the technology shall be warranted for the first 2 years following commencement of use of technology unit. The permittee shall have an inventory of replacement parts available locally or available for delivery within 24 hours.
- 1.13 All conditions set forth in WW Permits that include the use of the approved technology shall remain in effect and may surpass the conditions set herein.
- 1.14 A WW Permit that approves the use of a technology approved by this permit remains valid for the use of the technology identified in the WW Permit even if this permit expires.

## 2. DOCUMENTS

- 2.1 The approval of the I/A technology is based on the following documents submitted by the permittee:

<b>Title</b>	<b>Submission Date</b>	<b>Revision</b>
<b>VT Arc by Infiltrator Design and Installation Manual</b>	07/22/2020	09/22/2020
<b>VT-ANR Innovative and Alternative Technology Renewal Application</b>	02/28/2024	None

- 2.2 Use of the I/A technology in ways not depicted or described in the documents, and or identified in this permit, is not allowed without prior approval by the Drinking Water and Groundwater Protection Division.

## 3. Inspection and Diagnostic Professionals

- 3.1 The Permittee has designated all Vermont Licensed Wastewater Designers Class 1, B, and BW as Inspection and Diagnostic Professionals for the State of Vermont (Vermont I/D Professional) to

perform the inspections, maintenance, and repairs to the technology required by this permit and by conditions of the WW Permit.

- 3.2 The Permittee shall maintain a minimum of three Vermont I/D Professionals. Failure to maintain a minimum of three Vermont I/D Professionals will result in the Secretary prohibiting the issuance of a WW Permit with the approved technology.
- 3.3 The Permittee deems that all Vermont Licensed Wastewater Designers Class 1, B, and BW as having sufficient knowledge and understanding for the proper installation, operation, maintenance, and repair of each approved technology.
- 3.4 I/D Professionals must follow Permittee and WW Permit conditions for inspection, maintenance, and reporting requirements.
- 3.5 Maintenance and inspections of the approved technology must be performed by an I/D Professional authorized by the Permittee. Reports shall be provided to the Permittee, landowner, and Division in a timely manner so that they can ensure conditions of the WW Permits are met.
- 3.6 Maintenance and inspections performed by I/D Professionals shall be in accordance with the operation and maintenance manual submitted as part of the I/A permit approval application, as provided in trainings by the Permittee, and specified in the WW Permits issued by this Division.
- 3.7 Any performance issues with this technology including, but not limited to premature failure of the system, must be reported to the Permittee by a Vermont I/D Professional within 72 hours, so that the Permittee may be involved in the determination of the cause and be able to meet reporting requirements to the Division.

#### 4. REPORTS

- 4.1 The Permittee shall submit electronically by April 1<sup>st</sup> of each year an annual report to the Division containing the following information for the previous 12-month period ending December 31<sup>st</sup>:
  - A. the entities who are distributing the permitted technology in the State of Vermont
  - B. an analysis of all sites that were deemed to have a performance issue involving the technology including, but not limited to premature failure of the system and include:
    - i. the corresponding WW Permit number;
    - ii. the property's SPAN number;
    - iii. the name of the installer;
    - iv. the name of the Vermont-licensed Designer who was involved in the determination that there was a performance issue with the system;
    - v. the name of the Vermont-licensed Designer who provided the installation certification;
    - vi. the date installed;
    - vii. the date a performance issue was determined to exist;
    - viii. a description of the performance issue;
    - ix. potential/known causes of the performance issue;
    - x. a listing of the required repair/remediation;
    - xi. and identification of changes to the technology specification.
- 4.2 The Permittee shall ensure the Vermont I/D Professionals for each of the permitted systems utilizing this technology installed in Vermont are submitting to the Division the following reports:
  - A. an inspection report of the I/A technology for those systems which specify an inspection in the WW Permit.
- 4.3 Maintenance and inspections reports shall be submitted on the Secretary-approved inspection report form and be signed and dated by the I/D Professional.
- 4.4 Inspection reports by the I/D Professional shall include but not be limited to a summary of all known problems, damages, and/or failures of the technology to comply with this approval and operating requirements for the technology, including:

- A. a description of any problems, damages, and/or failures;
  - B. potential/known causes of any problems, damages, and/or failures;
  - C. a statement of system operability including whether or not the technology is operating in compliance with this approval and operating specifications following repairs or corrections of any problems, damages, and/or failures;
  - D. a listing of the required repair/remediation;
  - E. identification of changes to the technology specifications; and
  - F. any observed failure of the wastewater system including wastewater exposed to the open air, wastewater pooling on the surface of the ground, wastewater discharging directly to surface water, or wastewater backing up into the building or structure.
- 4.4 Problems, damages, and/or failures of the technology identified during an inspection per condition 4.3 of this permit must be reported by the service provider immediately to the landowner and within 30 days to the Division.
- 4.5 Maintenance and inspections shall be performed in accordance with the permitted operation and maintenance manual that are specified in the WW Permits issued by this Division.

## 5. DESIGN SPECIFICATIONS


- 5.1 The design of a wastewater system using the approved technology shall identify the specific approved -model and shall not be replaced with any other model without an amendment to the WW Permit.
- 5.2 Technologies shall be equipped with anti-flotation devices. The Permittee may specify whether or not the anti-flotation device are required if a designer demonstrates flotation will not occur or the designer proposes in an application for the use of the technology an alternative method to stabilize the technology that complies with the Permittee's requirements for installation.
- 5.3 Technology model choice and sizing shall be in accord with the Permittee's technical requirements approved by the Secretary. Sizing of each unit shall be based on the calculated design flow per § 1-803 of the Rules.

## 6. INSTALLATION SPECIFICATIONS

- 6.1 The approved technology shall be installed under the guidance of a designer.
- 6.2 The installation of each technology shall be in accordance with the Permittee's technical requirements approved by the Secretary.

Any person aggrieved by this permit may appeal to the Environmental Court within 30 days of the date of issuance of this permit in accordance with 10 V.S.A. Chapter 220 and the Vermont Rules of Environmental Court Proceedings.

Julia S. Moore, Secretary  
Agency of Natural Resources

By  Revised April 30, 2024  
Cristin Ashmankas, Environmental Analyst VII  
Wastewater System and Potable Water Supply Program  
Drinking Water and Groundwater Protection Division