



State of Vermont

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation

Wastewater Management Division
103 South Main Street - The Sewing Building
Waterbury VT 05671-0405
Phone: 802-241-3822
Fax: 802-241-2596

Department of Fish and Wildlife
Department of Forests, Parks, and Recreation
Department of Environmental Conservation
State Geologist
RELAY SERVICES FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

September 27, 2005

Ms. Kelly Blandford
Bio-Microbics, Inc.
8450 Cole Parkway
Shawnee, KS 66227

Re: Bio-Microbics SaniTEE®, Approval

Dear Ms. Blandford:

This letter is written in response to your letter of September 22, 2005, requesting approval of the four inch SaniTEE® effluent wastewater screen, manufactured by Bio-Microbics, Inc., in accordance with the Environmental Protection Rules, Chapter 1, Wastewater System and Potable Water Supply Rules, effective January 1, 2005.

Section §1-508(e) of the Rules states that all septic tank installations shall include an effluent filter approved by the Secretary. The only requirement of the filter is that it shall prevent passage of solids larger in size than 1/8 inch. Based on the information you have submitted, it appears that the four inch SaniTEE® effluent wastewater screen, manufactured by Bio-Microbics, Inc., meets the requirements of the Rules and can therefore be used in septic tank installations in Vermont.

If you have any questions, please contact me at 802-241-3686.

Sincerely,

Frank R. O'Brien, P.E.
Innovative Systems Engineer

Cc (Electronic): Roger Thompson, Jr., Regional Office Program Manager
Technical Advisory Committee
Regional Engineers

U:\Innovative System\092705.Bio-Microbics.SaniTEE.approval.doc