



State of Vermont

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist
RELAY SERVICE FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation

Wastewater Management Division
103 South Main Street - The Sewing Building
Waterbury VT 05671-0405
Phone: 802-241-3822
Fax: 802-241-2596
February 19, 2003

Mr. Patrick Mulhall, VP Sales/Marketing
Polylok, Inc.
173 Church Street
Yalesville, CT 06492

Re: Ploylok Effluent Filter PL-122

Mr. Mulhall:

This letter is written in response to your letter of December 12, 2002 to Roger Thompson, requesting approval of the PL-122 Effluent Filter manufactured by Polylok, Inc. in accordance with the Environmental Protection Rules, Chapter 1, Wastewater System and Potable Water Supply Rules. The Rules, which became effective on August 16, 2002, were prepared by the Wastewater Management Division of the Vermont Agency of Natural Resources, Department of Environmental Conservation.

Section § 1-508(e) of the Rules states that all septic tank installations shall include an effluent filter approved by the Secretary. The only requirement of the filter is that it shall prevent passage of solids larger in size than 1/8 inch. Based on the information you have submitted and an examination of the sample filter, it appears that the PL-122 Effluent Filter manufactured by Polylok, Inc. meets the requirements of the Rules and can therefore be used in septic tank installations in Vermont.

If you have any questions please contact me at 802-241-3686.

Sincerely,

Frank R. O'Brien
Innovative Systems Engineer

cc: Roger Thompson, Jr., Regional Office Program Manager

H:\Innovative System\0219Polylok03.doc



State of Vermont

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist
RELAY SERVICE FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation

Wastewater Management Division
103 South Main Street - The Sewing Building
Waterbury VT 05671-0405
Phone: 802-241-3822
Fax: 802-241-2596
January 9, 2004

Ms. Betsy Chaffet, Sales Representative
Polylok, Inc.
173 Church Street
Yalesville, CT 06492

Re: Polylok Effluent Filter PL-68

Dear Ms. Chaffet:

This letter is written in response to your letter of December 15, 2003 to Roger Thompson, requesting approval of the PL-68 Effluent Filter manufactured by Polylok, Inc. in accordance with the Environmental Protection Rules, Chapter 1, Wastewater System and Potable Water Supply Rules. The Rules, which became effective on August 16, 2002, were prepared by the Wastewater Management Division of the Vermont Agency of Natural Resources, Department of Environmental Conservation.

Section § 1-508(e) of the Rules states that all septic tank installations shall include an effluent filter approved by the Secretary. The only requirement of the filter is that it shall prevent passage of solids larger in size than 1/8 inch. Based on the information you have submitted and an examination of the sample filter, it appears that the PL-68 Effluent Filter manufactured by Polylok, Inc. meets the requirements of the Rules and can therefore be used in septic tank installations in Vermont.

If you have any questions please contact me at 802-241-3686.

Sincerely,

Frank R. O'Brien
Innovative Systems Engineer

cc: Roger Thompson, Jr., Regional Office Program Manager

U:\Innovative System\PolylokFilterPL-68.doc



State of Vermont

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist
RELAY SERVICE FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

AGENCY OF NATURAL RESOURCES Department of Environmental Conservation

Wastewater Management Division
103 South Main Street - The Sewing Building
Waterbury VT 05671-0405
Phone: 802-241-3822
Fax: 802-241-2596

January 24, 2005

Mr. Patrick Mulhall, V.P. Sales
Polylok, Inc.
173 Church Street
Yalesville, CT 06492

Re: Polylok Effluent Filter PL-525

Dear Mr. Mulhall:

This letter is written in response to your letter of January 21, 2005, requesting approval of the PL-525 Effluent Filter manufactured by Polylok, Inc. in accordance with the Environmental Protection Rules, Chapter 1, Wastewater System and Potable Water Supply Rules, effective January 1, 2005.

Section §1-508(e) of the Rules states that all septic tank installations shall include an effluent filter approved by the Secretary. The only requirement of the filter is that it shall prevent passage of solids larger in size than 1/8 inch. Based on the information you have submitted and an examination of the sample filter, it appears that the PL-525 Effluent Filter manufactured by Polylok, Inc. meets the requirements of the Rules and can therefore be used in septic tank installations in Vermont.

If you have any questions, please contact me at 802-241-3686.

Sincerely,

Frank R. O'Brien
Innovative Systems Engineer

cc: Roger Thompson, Jr., Regional Office Program Manager
Technical Advisory Committee
Regional Engineers

U:\Innovative System\PolylokFilterPL-525.doc