



Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation

Innovative/Alternative System Approval
General Use per §1-309 of the
Wastewater System and Potable Water Supply Rules, effective January 1, 2005

#2003-01-R1 (2006 Renewal)

Vendor Information

SPEC Industries, Inc.
550 Parkson Road
Henderson, Nevada 89015

Technology Name

AIRR Wastewater Treatment &
Recovery System

Contact

Roger J. Owley, President
SPEC Industries, Inc.
550 Parkson Road
Henderson, Nevada 89015
Phone (702) 558-4444
Fax (702) 558-4563
Email: rogero@specind.biz
Web: www.specind.biz

Technology Type

Alternating Intermittent
Recirculating Reactor

Expiration Date

July 1, 2008

Approval

The SPEC AIRR Simplex Unit, Model S – 480L, AIRR 77 Unit – Two Bedroom, or AIRR 714 Unit – Four Bedroom, may be used as part of a subsurface wastewater disposal system approved under the Wastewater System and Potable Water Supply Rules, effective January 1, 2005 (Rules), under the following conditions:

1. The treatment units must be installed and operated as described in the Innovative/Alternative System application package filed with the Agency of Natural Resources (Agency) on May 20, 2003.
2. Unit sizing must be in accord with the technical information submitted with the Innovative/Alternative System application package on May 20, 2003. The sizing shall be based on the calculated design flow per §1-504 of the Rules.

Innovative/Alternative System Approval
#2003-01-R1 (2006 Renewal)

3. This approval is based on treatment only of domestic wastewater of low and moderate strength as specified in §1-519(a)(1)(C) & (D) of the Rules.
4. The system may be used for both new and replacement systems.
5. All effluent from a SPEC AIRR Wastewater Treatment & Recovery System shall be discharged to a filtrate disposal system that conforms to the requirements of §1-520 of the Rules. If the rules are revised during the term of this approval, this approval may be revised as needed to conform to the revisions.
6. Each application for use shall demonstrate the ability to construct a fully complying replacement system.
7. Detailed operating instructions shall be provided in writing to the owner/operator.
8. The vendor shall have an inventory of replacement parts available locally.
9. The vendor shall provide a copy of this approval letter to any landowner who is a prospective purchaser of a SPEC AIRR Wastewater Treatment & Recovery System prior to the sale of the system and prior to the filing of any application for a site-specific approval by the Agency for the purchaser's property. The application filed with the Agency shall include the landowner's written acknowledgement of this approval letter. Prior to any sale of the property or completion of a sales agreement to sell the property, a copy of the site-specific permit shall be provided to the prospective purchaser.
10. The owner of a property where a SPEC AIRR Wastewater Treatment & Recovery System has been installed shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency. Maintenance shall be performed or supervised by a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accord with the manufacturers Operation and Maintenance requirements submitted as part of the Innovative/Alternative System application package. If at any inspection the effluent is cloudy or pungent smelling a sample shall be collected and tested for BOD and TSS. The results of any testing shall be submitted with the annual inspection report.

11. The first inspection shall be completed no later than 6 months after placing the system in service. The second inspection shall be completed no later than 12

Innovative/Alternative System Approval
#2003-01-R1 (2006 Renewal)

months after placing the system in service. Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service. More frequent inspections or additional testing, required by the manufacturer to ensure proper functioning of the system, shall be conducted in accordance with the manufacturer's specifications. All reports shall be filed with the appropriate Regional Environmental Office of the Agency, the Vendor and the landowner with the annual inspection report.

12. The vendor shall submit an annual report to the Agency by April 1 of each year containing the following information for the 12 month period ending December 31 of the previous year:
 - A. The number of permitted systems installed in Vermont, including those permitted by the Agency and those permitted by Towns under authority of 24 V.S.A. Chapter 102.
 - B. The address of each installation.
 - C. The name of the owner at the time of installation and any known change in ownership.
 - D. All known problems or failures, with a brief summary of the cause and remedial measures taken.
13. This approval is based on information submitted by the Vendor indicating that the SPEC AIRR Simplex Unit, Model S – 480L, AIRR 77 Unit – Two Bedroom, or AIRR 714 Unit – Four Bedroom will routinely provide effluent with no more than 30 mg/l of BOD₅ or more than 30 mg/l of TSS.
14. When the project is subject to the Rules, site-specific permission for the use of this product is required in the form of a Wastewater System and Potable Water Supply Permit.
15. A site-specific permit for the use of this system may be revoked if the system fails to function properly or if the property owner fails to have a valid contract for the required maintenance and inspection of the system. In the case of the unit failing to function properly, revocation of the permit will require that the use of the building be discontinued unless another wastewater disposal system is installed based on prior written approval by the Agency.
16. A town that regulates wastewater disposal systems under 24 V.S.A., Chapter 102 and whose ordinance permits, may approve use of a SPEC AIRR Wastewater Treatment & Recovery System subject to all conditions in this approval. The town shall ensure that the maintenance contract is in effect and that the required maintenance is performed.

Innovative/Alternative System Approval
#2003-01-R1 (2006 Renewal)

17. This approval is not a representation or guarantee of the effectiveness, efficiency or operation of this system.

Design and Review Conditions

The following conditions will be used by the Department in reviewing permit applications that include a SPEC AIRR Wastewater Treatment & Recovery System:

Equipment

- SPEC AIRR Simplex Unit, Model S – 480L, AIRR 77 Unit – Two Bedroom, AIRR 714 Unit – Four Bedroom

Design and Application

- The treatment unit shall be designed by a Licensed Class 1 Designer or a Licensed Class B Designer in accordance with the manufacturer's recommendations. The designer shall assure that the system will properly function in all seasons
- The designer must assess the structural needs of the unit for the specific application site and place the requirements on the design plans.
- The designer must determine the type of backfill required and any necessary placement specification.
- The designer must assess the ventilation path for the particular application and make any necessary provisions to assure proper flow and control of odor emissions.
- The designer shall include in the design a septic tank effluent filter with easy access for inspection and cleaning.
- The designer shall consult with the Vendor for proper sizing.
- The designer must assure routine access to each compartment of the unit (access to grade) as well as the control panel, any pumps, distribution boxes (for sampling), and effluent filters.
- The designer must address flotation issues if the SHWT will be above the bottom of any of the tanks.

Installation Inspection

Innovative/Alternative System Approval
#2003-01-R1 (2006 Renewal)

- The treatment unit shall be set up under the instruction and guidance of an installer/inspector trained by the manufacturer.
- The treatment unit shall be inspected by a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor, after construction of the unit and installation of the tanks before backfilling, and after backfilling and grading is complete. The inspection shall include checking for an adequate structural foundation to support the unit, checking for levelness of the tanks, and inspecting for damage and proper assembly.
- Before backfilling, the unit and tankage shall be tested for watertightness by filling the unit or tank with water and holding it at a constant level for 24 hours; there shall be no measurable leakage. During the test the entire unit and tanks shall be inspected for visible leaks. Should the unit or tanks fail the test they may be repaired and retested. The testing and repairs shall be conducted under the direction and in the presence of the inspecting Licensed Designer.
- The Licensed Designer shall inspect all piping for proper installation and watertightness before backfilling.

Start-up

- Start-up of the system and initial operational checks shall be conducted by an installer/inspector trained by the Vendor, who shall submit a report to the owner, the Vendor, and to the inspecting Licensed Class 1 Designer or Licensed Class B Designer indicating any problems encountered, their resolution, and affirmation that the system is operating as intended.

Operational Maintenance and Inspection

- The owner shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency. Maintenance shall be performed by, or shall be supervised by, a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accord with the manufacturers Operation and Maintenance Manual submitted as part of the Innovative/Alternative System application package. If at any inspection the effluent is cloudy or

Innovative/Alternative System Approval
#2003-01-R1 (2006 Renewal)

pungent smelling a sample shall be collected and tested for BOD₅ and TSS. The results of any testing shall be submitted with the annual inspection report.

- The first inspection shall be completed no later than 6 months after placing the system in service.
- The second inspection shall be completed no later than 12 months after placing the system in service.
- Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service. More frequent inspections or additional testing, required by the manufacturer to ensure proper functioning of the system, shall be conducted in accordance with the Vendor's specifications.
- All reports shall be filed with the appropriate Regional Environmental Office of the Agency, the Vendor, and the landowner with the annual inspection report.

Permitting

- The permit shall run with the land.
- A copy of the site-specific permit shall be provided to any prospective purchaser prior to the sale.
- Each new owner of the property shall inform the appropriate Regional Environmental Office of the Agency, and the Vendor, within 30 days of the transfer of the property and include the name and mailing address of the new owner.

Effective August 30, 2006

by Roger Thompson Jr
Roger Thompson, Jr.
Regional Office Program Manager