

**State of Vermont**  
**Department of Environmental Conservation**  
**Drinking Water & Groundwater Protection Division**  
1 National Life Drive – Main 2  
Montpelier VT 05620-3521  
<http://www.anr.state.vt.us/dec/dwgwp/index.htm>

*Agency of Natural Resources*  
[phone] 802-585-4911

December 22, 2017

Mr. Bruce Stowe  
Roth Global Plastics and Roth Industries  
P.O. Box 245  
Syracuse, NY 13211  
Email: [bruces@roth-usa.com](mailto:bruces@roth-usa.com)

Dear Mr. Stowe,

**RE: No objection to use Roth MultiTanks (RMT) for septic tanks and effluent pump stations**

Following your email of October 5, 2017 requesting that Roth MultiTank (RMT) models already approved for use as septic tanks in Vermont receive additional approval for use as effluent pump station tanks, I have reviewed the tank specifications against the Vermont Wastewater Supply and Potable Water Supply Rules (Rules). I can confirm that based on the information provided, the RMT models meet the tank requirements of Appendix 1-A-01 'Sewage Lift Stations' and Appendix 3-A-01 'Septic Tank Specifications and Maintenance'.

The Roth MultiTank models RMT-300, 500, 750, 900, 1000E, 1060, 1250, 1500 may be used as septic tanks and/or pump tanks in Vermont providing that they are designed and installed according to the manufacturers recommendations, including where necessary the installation instructions for high groundwater conditions. The overall wastewater system design, including the pump specifications used in conjunction with the tank shall be reviewed at the time of the site-specific permit application.

If you have any questions, please don't hesitate to call me at 802 622-4129 or email me at [grahame.bradley@vermont.gov](mailto:grahame.bradley@vermont.gov).

Sincerely,



Dr. J. Graham Bradley  
DWGWP Innovative / Alternative Systems Approval

cc: Regional Engineers

