

State of Vermont

AGENCY OF NATURAL RESOURCES Department of Environmental Conservation

Department of Fish and Wildlife

Department of Forests, Parks, and Recreation

Department of Environmental Conservation

Innovative/Alternative System Approval

State Geologist

RELAY SERVICES FOR THE HEARING IMPAIRED

1-800-253-0191 TDD>Voice 1-800-253-0195 Voice>TDD #2001-01 (2005 Renewal)

Vendor Information

Orenco Systems, Inc. 814 Airway Avenue

Sutherlin, OR 97479

Contact

Orenco Systems, Inc. 814 Airway Avenue

Sutherlin, OR 97479

(541) 459-4449

Fax (541) 459-2884

Web Site: www.orenco.com

Contact: Sam Carter

Local Contact

David Cotton

Wastewater Technologies, Inc.

19 Precast Road

Milton, VT 05468

Tel: 877-212-3219

802-893-6581

Fax:

802-893-6605

wti@wastewatertechnologies.com

www.wastewatertechnologies.com

Approval

The AdvantexTM Treatment System operating in Modes AX-1 and AX-3 may be used as part of a subsurface wastewater disposal system approved under the Wastewater System and Potable Water Supply Rules, effective January 1, 2005 under the following conditions:

 The treatment units must be installed and operated as described in the Innovative/Alternative System application package filed with the Agency of Natural Resources (Agency) on March 1, 2001.

Technology Name

Advantex TM Treatment System

Technology Type

Textile Based Recirculating Packed

Bed Filter

Expiration Date

September 15, 2007

- Unit sizing must be in accord with the technical information submitted with the Innovative/Alternative System application package on March 1, 2001. The sizing shall be based on the calculated design flow per §1-504 of the Wastewater System and Potable Water Supply Rules, effective January 1, 2005.
- This approval is based on treatment only of domestic wastewater of low and moderate strength as specified in §1-519(a)(1)(C) & (D) of the Wastewater System and Potable Water Supply Rules, effective January 1, 2005.
- The system may be used for both new and replacement systems.
- 5. All effluent from the AdvantexTM Treatment System shall be discharged to a filtrate disposal system that conforms to the requirements of §1-520 of the Wastewater System and Potable Water Supply Rules, effective January 1, 2005. If the rules are revised during the term of this approval, this approval shall be revised as needed to conform to the revisions.
- Each application for use shall demonstrate the ability to construct a fully complying replacement system
- All treatment modules shall be equipped with anti-flotation flanges unless there is a demonstration that flotation is not a problem on a particular site or that an alternative system has been approved by the Agency.
- Detailed operating instruction shall be provided in writing to the owner/operator.
- The vendor shall have an inventory of replacement parts available locally.
- The vendor shall provide a copy of this approval letter to any landowner who is a prospective purchaser of an AdvantexTM Treatment System prior to the sale of the system and prior to the filing of any application for a site-specific approval by the Agency for the purchaser's property. The application filed with the Agency shall include the landowner's written acknowledgement of this approval letter. Prior to any sale of the property or completion of a sales agreement to sell the property, a copy of the site-specific permit shall be provided to the prospective purchaser.
- 11. The owner of a property where an AdvantexTM system has been installed shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency. Maintenance shall be performed by, or shall be supervised by, a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor or their representative, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the

system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accordance with the manufacturer's Operation and Maintenance Manual submitted as part of the Innovative/Alternative System application package. If at any inspection the effluent is cloudy or pungent smelling a sample shall be collected and tested for BOD₅ and TSS. The results of any testing shall be submitted with the annual inspection report.

- 12. The first inspection shall be completed no later than 6 months after placing the system in service. The second inspection shall be completed no later than 12 months after placing the system in service. Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service. More frequent inspections or additional testing, required by the manufacturer to ensure proper functioning of the system, shall be conducted in accordance with the manufacturer's specifications. All reports shall be filed with the appropriate Regional Environmental Office of the Agency and the land owner no later than 30 days after the date of inspection.
- 13. All systems shall be equipped with an hour meter, an audible alarm, and a visual alarm. These indicators shall be located outside of any buildings and visible to the building users in the normal course of routine occupancy of the building.
- 14. The vendor shall submit an annual report to the Agency by April 1st of each year containing the following information for the previous 12 month period ending December 31st of the previous year:
 - A. The number of permitted systems installed in Vermont, including those permitted by the Agency and those permitted by Towns under authority of 24 V.S.A. Chapter 102.
 - The address of each installation.
 - C. The name of the owner at the time of installation and any known change in ownership.
 - D. All known problems or failures, with a brief summary of the cause and remedial measures taken.
- This approval is based on information submitted by the Vendor indicating that the specified models and treatment modes will routinely provide effluent with no more than 30 mg/l of BOD₅ or more than 30 mg/l of TSS.
- When a project is subject to the Wastewater System and Potable Water Supply Rules, effective January 1, 2005, site specific permission for the use of this

product is required in the form of a Wastewater System and Potable Water Supply Permit.

- 17. A site specific permit for the use of this system may be revoked if the system fails to function properly or if the property owner fails to have a valid contract for the required maintenance and inspection of the system. Revocation of the permit will require that the use of the building be discontinued unless another wastewater disposal system is installed based on prior written approval by the Agency.
- 18. A town that regulates wastewater disposal systems under 24 V.S.A., Chapter 102 and whose ordinance permits, may approve use of the AdvantexTM Treatment System subject to all conditions in this approval. The town shall ensure that the maintenance contract is in effect and that the required maintenance is performed.
- This approval is not a representation or guarantee of the effectiveness, efficiency or operation of an AdvantexTM Treatment System.

Design and Review Conditions

The following conditions will be used by the Department in reviewing permit applications that include an AdvantexTM Treatment System:

Equipment

AdvantexTM Treatment System operating in Modes AX-1 and AX-3.

Design and Application

- The treatment unit shall be installed in accordance with the approved plans and the manufacturer's recommendations. The designer shall assure that the system will properly function in all seasons.
- The designer must assess the structural needs of the unit for the specific application site and place the requirements on the design plans.
- The designer must determine the type of backfill required and any necessary placement specification.
- The designer must assess the ventilation path for the particular application and make any necessary provisions to assure proper flow and control of odor emissions.
- The designer shall include in the design a septic tank effluent filter with easy access for inspection and cleaning.

- The designer must assure routine access to the unit as well as the septic tank effluent filter.
- The designer must address flotation issues if the SHWT will be above the bottom of any of the tanks.

Installation Inspection

- The treatment unit shall be set up under the instruction and guidance of an installer/inspector trained by the manufacturer.
- The treatment unit shall be inspected by a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor, after construction of the unit and installation of the tanks before backfilling, and after backfilling and grading is complete. The inspection shall include checking for an adequate structural foundation to support the unit, checking for levelness of the tanks, and inspecting for damage and proper assembly.
- Before backfilling, the unit and tankage shall be tested for watertightness by filling the unit or tank with water and holding it at a constant level for 24 hours; there shall be no measurable leakage. During the test the entire unit and tanks shall be inspected for visible leaks. Should the unit or tanks fail the test they may be repaired and retested. The testing and repairs shall be conducted under the direction and in the presence of the inspecting Licensed Class 1 Designer or a Licensed Class B Designer.
- The Licensed Class 1 Designer or a Licensed Class B Designer shall inspect all piping for proper installation and watertightness before backfilling.

Start-up

Start-up of the system and initial operational checks shall be conducted by an installer/inspector trained by the manufacturer, who shall submit a report to the owner, and to the inspecting Licensed Class 1 Designer or a Licensed Class B Designer indicating any problems encountered, their resolution, and affirmation that the system is operating as intended.

Operational Maintenance and Inspection

The owner shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency. Maintenance shall be performed by, or shall be supervised by, a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor, who shall provide written inspection reports detailing the maintenance performed on the specific

system, any problems that have occurred since the previous inspection, any modifications made to the system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accord with the manufacturers Operation and Maintenance Manual submitted as part of the Innovative/Alternative System application package. If at any inspection the effluent is cloudy or pungent smelling a sample shall be collected and tested for BOD₅ and TSS. The results of any testing shall be submitted with the annual inspection report.

- The first inspection shall be completed no later than 6 months after placing the system in service.
- The second inspection shall be completed no later than 12 months after placing the system in service.
- Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service.
- All inspection reports shall be filed with the appropriate Regional Environmental Office of the Agency and the landowner no later than 30 days after the date of inspection.

Permitting

- The permit shall run with the land.
- A copy of the permit shall be provided to any prospective buyers prior to the sale.
- Each new owner of the property shall inform the appropriate Regional Environmental Office of the Agency within 30 days of the transfer of the property and include the name and mailing address of the new owner.

Effective September, 23, 2005

ву_

Roger Thompson,

Regional Office Program Manager

U:\Innovative System\AdvantexApproval-05Renewal.doc