



State of Vermont

Agency of Natural Resources

Drinking Water and Groundwater Protection Division
1 National Life Drive, Main 2
Montpelier VT 05620-3521
Telephone: 802-585-4911

Innovative/Alternative System Approval
General Use per §1-1001 of the
Wastewater System and Potable Water Supply Rules, effective September 29, 2007

Approval Number: 2006-04-R2
Approval Date: June 23, 2015

Vendor Information

Infiltrator® Water Technologies, LLC
4 Business Park Road
P. O. Box 768
Old Saybrook, CT 06475

Technology Name

Standard Chamber, Standard
Sidewinder, High Capacity,
Equalizer 24, Equalizer 36,
Quick 4 Equalizer 24, Quick 4 Plus
Equalizer 24 LP, Quick 4 Standard.,
Quick 4 High Capacity, Quick 4
Equalizer 36, Quick 4 Plus Standard,
Quick 4 Plus Standard LP, Quick 4
Plus Equalizer 36 LP, and Quick 4
Plus High Capacity

Contact

Mr. David Lentz, P.E.,
Regulatory Director
Phone: (800) 221-4436
Fax: (860) 577-7001
Email: dlentz@infiltratorsystems.net
Web: www.infiltratorsystems.com

Technology Type

Gravelless Leaching Chamber
Dispersal System

Expiration Date

September 22, 2016

Approval

The Infiltrator Series Chambers may be used as part of a subsurface wastewater disposal system approved under the Wastewater System and Potable Water Supply Rules, effective September 29, 2007 under the following conditions:

1. The Infiltrator Series Chamber wastewater disposal systems must be designed, installed, and operated in accordance with the Rules and the manufacturer's recommendations. No distribution piping is required within the Infiltrator

Innovative/Alternative System Approval
#2006-04-R2

Chamber systems, unless otherwise required by the Rules including but not limited to, mound, at-grade, and filtrate effluent wastewater disposal systems.

2. System sizing must be in accord with the Rules and the manufacturer's recommendations, except that the allowable application rate may be increased by up to two times that allowed for a conventional pipe and stone system based on the application of septic tank effluent. Application of filtrate effluent will be sized at the same rate per square foot of bottom area as for conventional pipe and stone systems applying filtrate effluent. As with a conventional pipe and stone system, only the uncovered bottom area of the trench or bed may be used when calculating the system size. The sizing shall be based on the calculated design flow per §1-808 of the Rules. The equivalent bottom area for each product is as follows:

Standard Chamber	Contact Infiltrator	
Standard Sidewinder	Contact Infiltrator	
High Capacity	Contact Infiltrator	
Equalizer 24	Contact Infiltrator	
Equalizer 36	Contact Infiltrator	
Quick 4 Equalizer 24	Contact Infiltrator	
Quick4 Plus Equalizer 24 LP	Contact Infiltrator	
Quick 4 Standard unit	4.54 ft ² per linear foot	18.2 ft ² per
Quick 4 High Capacity unit	4.54 ft ² per linear foot	18.2 ft ² per
Quick 4 Equalizer 36 per unit	3.22 ft ² per linear foot	12.9 ft ² per
Quick4 Plus Standard per unit	4.54 ft ² per linear foot	18.2 ft ² per
Quick4 Plus Standard LP unit	4.54 ft ² per linear foot	18.2 ft ² per
Quick4 Plus Equalizer 36 LP unit	3.22 ft ² per linear foot	12.9 ft ² per
Quick4 Plus High Capacity unit	4.96 ft ² per linear foot	19.8 ft ² per

The End Cap parts are sized as follows, per pair:

Quick4 Standard Multiport Endcap	7.1	SF/Pair
Quick4 Plus Standard LP Endcap	2.24	SF/Pair
Quick4 Plus Standard LP All-in-One 8 Endcap	6.6	SF/Pair
Quick4 High Capacity Multiport Endcap	8.9	SF/Pair
Quick4 Plus Equalizer 36 LP Endcap	2.24	SF/Pair
Quick4 Plus Equalizer 36 LP All-in-One 8 Endcap	6.6	SF/Pair
Quick4 Equalizer 36 Multiport Endcap	4.6	SF/Pair

Innovative/Alternative System Approval
#2006-04-R2

3. This approval is based on disposal only of domestic wastewater of low and moderate strength as specified in §1-915(a)(1)(C) & (D) of the Rules. Systems to treat higher strength wastes may be approved by the Secretary on a case-by-case basis with the Vendor's agreement.
4. The Infiltrator Chambers may be used for both new and replacement systems.
5. If the Rules are revised during the term of this approval, this approval may be revised as need to conform to the revisions.
8. Site-specific approval for the use of this product is required in the form of a Wastewater System and Potable Water Supply Permit.
9. A site-specific permit for the use of this product may be revoked if the system fails to function properly. Revocation of the permit will require that the use of the building be discontinued unless another wastewater disposal system is installed based on prior written approval by the Agency.
10. This approval is not a representation or guarantee of the effectiveness, efficiency or operation of an Infiltrator Chamber wastewater disposal system.

Landowner Requirements

1. A copy of the permit shall be provided to any prospective purchaser prior to the sale.
2. Each new landowner of the property shall inform the appropriate Regional Office of the Agency within 30 days of the transfer of the property and include the name and mailing address of the new owner.

Vendor Requirements

1. The vendor shall submit an annual report to the Agency by April 1 of each year for the 12 month period ending December 31 of the previous year. The report shall contain the following information:
 - A. All known new permitted systems installed in Vermont for the previous year including:
 - i. Assigned WW permit number;
 - ii. Physical and landowner mailing addresses;
 - iii. Name of current landowner;
 - iv. Name of Designer providing the installation certification; and
 - v. Name of installer.
 - B. All known existing permitted systems with changes in ownership shall include the WW permit number; the physical and mailing address, and the name of the current landowner.

Innovative/Alternative System Approval
#2006-04-R2

- C. All known problems, damages and/or failures, including:
- i. Description of the issues;
 - ii. Potential/known causes of problems;
 - iii. System operability;
 - iv. Recommended repair/remediation;
 - v. Date(s) of repair/remediation; and
 - vi. System effectiveness.

Note: Repairs that are not defined by the Rules as a "Minor Repair" require approval by the Division prior to making the repair.

- D. A list of names of Designers and Installers trained by the vendor or their representative.

2. The vendor or their representative shall train and certify designers and installers in the proper use and installation of the Infiltrator Chambers.

Design and Review Conditions


The following conditions will be used by the Department in reviewing permit applications that include Infiltrator Chamber wastewater disposal systems designed in accordance with this approval:

Equipment

1. Infiltrator® Water Technologies, LLC Infiltrator Chambers

Design and Application

1. The Designer shall specify which chamber model is to be installed.
2. Within 30 days of this approval, the Vendor shall provide an updated Design and Installation Manual for Chambers in Vermont including the new chamber models.
3. The wastewater disposal system shall be designed by a Licensed Class 1 Designer or a Licensed Class B Designer in accordance with the manufacturer's recommendations including the approved Design and Installation Manual and the Rules.
4. In sizing the system, the designer may use an application rate of up to twice the rate allowed for septic tank effluent in a conventional pipe and stone wastewater disposal system. Only the uncovered bottom area of the trench or bed may be used when calculating system size.
5. The designer shall provide the landowner with written guidance on the maintenance requirements and homeowner responsibilities in the care and use of an onsite wastewater system.



Innovative/Alternative System Approval
#2006-04-R2

Installation Inspection

1. The wastewater disposal system shall be installed in accordance with the approved plans and under the instruction and guidance of an installer/inspector trained by the vendor.
2. The wastewater disposal system shall be inspected by a Licensed Class 1 Designer or a Licensed Class B Designer, approved by the Vendor, during installation of the system and installation of any tanks before backfilling, and after backfilling and grading is complete. The inspection shall include checking for levelness of the chambers, and inspecting for damage and proper assembly.
3. A Licensed Class 1 Designer or a Licensed Class B Designer shall inspect all transport piping for proper installation and watertightness before backfilling.
4. A letter certifying that the system is correctly installed (including the language specified in §1-308 of the Rules) shall be provided electronically to the vendor and the approving Regional Office that issued the permit.

Permitting

1. The permit shall run with the land.

Effective Date: June 23, 2015

By 
Ernest Christianson
Regional Office Program Manager