



State of Vermont

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist

Innovative/Alternative System Approval

RELAY SERVICES FOR HEARING IMPAIRED
1-800-253-0191 TDD>VOICE
1-800-253-0195 VOICE>TDD

#2002-02-R1 (Renewal) (Revised 08/26/04)

Vendor Information

Premier Tech
7051 Meadow Lark Drive
Birmingham, Alabama 35242

Technology Name

Ecoflo® Biofilter

Contact

Luke Robitaille
Premier Tech
7051 Meadow Lark Drive
Birmingham, Alabama 35242
(205) 408-9691
Fax (205) 408-8783

Technology Type

Single Pass Peat Filter

Expiration Date

April 30, 2006

Local Contact

Tim Lake
New England Biofilter Corporation
P.O. Box 912
Stowe, Vermont 05672
Tel: (802) 253-2203
Fax: (802) 253-7382

Approval

The Ecoflo® Biofilter Model STB-650 and Model STB-500 may be used as part of a subsurface wastewater disposal system approved under the Wastewater System and Potable Water Supply Rules, effective August 16, 2002 under the following conditions:

1. The treatment units must be installed and operated as described in the Innovative/Alternative System application package filed with the Agency of Natural Resources (Agency) on April 9, 2002 and on March 10, 2004.
2. Unit sizing must be in accord with the technical information submitted with the Innovative/Alternative System application package on April 9, 2002 and on March 10, 2004. The sizing shall be based on the calculated design flow per §1-504 of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002.

Innovative/Alternative System Approval
#2002-02-R1 (Renewal) (Revised 08/26/04)

3. This approval is based on treatment only of domestic wastewater of low and moderate strength as specified in §1-519(a)(1)(C) & (D) of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002.
4. The system may be used for both new and replacement systems.
5. All effluent from the Ecoflo® Biofilter shall be discharged to a filtrate disposal system that conforms to the requirements of §1-520 of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002. If the rules are revised during the term of this approval, this approval shall be revised as needed to conform to the revisions.
6. Each application for use shall demonstrate the ability to construct a fully complying replacement system.
7. Detailed operating instruction shall be provided in writing to the owner/operator.
8. The vendor shall have an inventory of replacement parts available locally.
9. The vendor shall provide a copy of this approval letter to any landowner who is a prospective purchaser of an Ecoflo® Biofilter prior to the sale of the system and prior to the filing of any application for a site-specific approval by the Agency for the purchaser's property. The application filed with the Agency shall include the landowner's written acknowledgement of this approval letter. Prior to any sale of the property or completion of a sales agreement to sell the property, a copy of the site-specific permit shall be provided to the prospective purchaser.
10. The owner of a property where an Ecoflo® Biofilter has been installed shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency. Maintenance shall be performed or supervised by a Vermont Licensed Professional Engineer or a Licensed Type B Designer, approved by the Vendor, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accordance with the manufacturer's Operation and Maintenance Manual submitted as part of the Innovative/Alternative System application package. If at any inspection the effluent is cloudy or pungent smelling a sample shall be collected and tested for BOD₅ and TSS. The results of any testing shall be submitted with the annual inspection report.

Innovative/Alternative System Approval
#2002-02-R1 (Renewal) (Revised 08/26/04)

11. The first inspection shall be completed no later than 6 months after placing the system in service. The second inspection shall be completed no later than 12 months after placing the system in service. Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service. All reports shall be filed with the appropriate Regional Environmental Office of the Agency and the land owner no later than 30 days after the date of inspection.
12. The vendor shall submit an annual report to the Agency by April 1st of each year containing the following information for the previous 12 month period ending December 31st of the previous year:
 - A. The number of permitted systems installed in Vermont, including those permitted by the Agency and those permitted by Towns under authority of 24 V.S.A. Chapter 102.
 - B. The address of each installation.
 - C. The name of the owner at the time of installation and any known change in ownership.
 - D. All known problems or failures, with a brief summary of the cause and remedial measures taken.
13. This approval is based on information submitted by the Vendor indicating that the specified models and treatment modes will routinely provide effluent with no more than 30 mg/l of BOD₅ or more than 30 mg/l of TSS.
14. When the project is subject to the Wastewater System and Potable Water Supply Rules, effective August 16, 2002 site specific permission for the use of this product is required in the form of a Wastewater System and Potable Water Supply Permit.
15. A site-specific permit for the use of this system may be revoked if the system fails to function properly or if the property owner fails to have a valid contract for the required maintenance and inspection of the system. Revocation of the permit will require that the use of the building be discontinued unless another wastewater disposal system is installed based on prior written approval by the Agency.
16. A town that regulates wastewater disposal systems under 24 V.S.A., Chapter 102 and whose ordinance permits, may approve use of an Ecoflo® Biofilter subject to all conditions in this approval. The town shall ensure that the maintenance contract is in effect and that the required maintenance is performed.

Design and Review Conditions

The following conditions will be used by the Department in reviewing permit applications that include an Ecoflo® Biofilter:

Equipment

- Ecoflo® Biofilter Model STB-650 and Model STB-500

Design and Application

- The treatment unit shall be installed in accordance with the approved plans and the manufacturer's recommendations. The designer shall assure that the system will properly function in all seasons.
- The designer must assess the structural needs of the unit for the specific application site and place the requirements on the design plans.
- The designer must determine the type of backfill required and any necessary placement specification.
- The designer must assess the ventilation path for the particular application and make any necessary provisions to assure proper flow and control of odor emissions.
- The designer shall include in the design a septic tank effluent filter with easy access for inspection and cleaning.
- The designer must assure routine access to the unit as well as the septic tank effluent filter.

Installation Inspection

- The treatment unit shall be set up under the instruction and guidance of an installer/inspector trained by the manufacturer.
- The treatment unit shall be inspected by a Professional Engineer Registered in Vermont as a civil, civil/sanitary, sanitary or environmental engineer or a Licensed Type B Designer, approved by the Vendor, after construction of the unit and installation of the tanks before backfilling, and after backfilling and grading is complete. The inspection shall include checking for an adequate structural foundation to support the unit, checking for levelness of the tanks, and inspecting for damage and proper assembly.
- Before backfilling, the unit and tankage shall be tested for watertightness in accordance with the manufacturer's recommendations. During the test the

Innovative/Alternative System Approval
#2002-02-R1 (Renewal) (Revised 08/26/04)

entire unit and tanks shall be inspected for visible leaks. Should the unit or tanks fail the test they may be repaired and retested. The testing and repairs shall be conducted under the direction and in the presence of the inspecting engineer or site technician.

- The engineer or site technician shall inspect all piping for proper installation and watertightness before backfilling.

Start-up

- Start-up of the system and initial operational checks shall be conducted by an installer/inspector trained by the manufacturer, who shall submit a report to the owner, and to the inspecting engineer or site technician indicating any problems encountered, their resolution, and affirmation that the system is operating as intended.

Operational Maintenance and Inspection

- The owner shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency. Maintenance shall be performed by, or shall be supervised by, a Vermont Registered Professional Engineer or a Licensed Type B Designer, approved by the Vendor, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accord with the manufacturers Operation and Maintenance Manual submitted as part of the Innovative/Alternative System application package. If at any inspection the effluent is cloudy or pungent smelling a sample shall be collected and tested for BOD₅ and TSS. The results of any testing shall be submitted with the annual inspection report.

- The first inspection shall be completed no later than 6 months after placing the system in service.
- The second inspection shall be completed no later than 12 months after placing the system in service.
- Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service.

Innovative/Alternative System Approval
#2002-02-R1 (Renewal) (Revised 08/26/04)

- All inspection reports shall be filed with the appropriate Regional Environmental Office of the Agency and the landowner no later than 30 days after the date of inspection.

Permitting

- The permit shall run with the land.
- A copy of the permit shall be provided to any prospective buyers prior to the sale.
- Each new owner of the property shall inform the appropriate Regional Environmental Office of the Agency within 30 days of the transfer of the property and include the name and mailing address of the new owner.

Effective 8/26/2004

By Roger Thompson, Jr.
Roger Thompson, Jr.
Regional Office Program Manager

U:\Innovative System\EcofloApproval-04Renewal.doc