



State of Vermont

AGENCY OF NATURAL RESOURCES
Department of Environmental Conservation

Department of Fish and Wildlife
Department of Forests, Parks and Recreation
Department of Environmental Conservation
State Geologist

RELAY SERVICE FOR THE HEARING IMPAIRED
1-800-253-0191 TDD>Voice
1-800-253-0195 Voice>TDD

Innovative/Alternative System Approval
General Use per §1-309 of the
Wastewater System and Potable Water Supply Rules, effective August 16, 2002

#2003-02

Vendor Information

Aquapoint, Inc.
241 Duchaine Boulevard
New Bedford, MA 02745

Contact

Chuck Resevick, Technical Sales
Aquapoint, Inc.
241 Duchaine Boulevard
New Bedford, MA 02745
Phone (508) 998-7577
Fax (508) 998-7177
Cell (508) 446-0303
Email: cresevick@aquapoint.com
Web: www.aquapoint.com

Technology Name

Bioclere

Technology Type

Recirculating Fixed Film
Trickling Filter

Expiration Date

December 1, 2005

Approval

The Bioclere Model Numbers 16/12/350, 16/15/600, 22/15/950, 24/24/1600, 24/30/950, 24/30/1600, 30/24, 36/24, and 36/30, may be used as part of a subsurface wastewater disposal system approved under the Wastewater System and Potable Water Supply Rules, effective August 16, 2002 under the following conditions:

1. The treatment units must be installed and operated as described in the Innovative/Alternative System application package filed with the Agency of Natural Resources (Agency) on May 20, 2003 and June 11, 2003, and with the site-specific installation and operating instructions submitted.
2. Unit sizing must be in accord with the technical information submitted with the Innovative/Alternative System application package on May 20, 2003 and June 11, 2003. The sizing shall be based on the calculated design flow per §1-504 of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002.

Innovative/Alternative System Approval
#2003-02

3. This approval is based on treatment only of domestic wastewater of low and moderate strength as specified in §1-519(a)(1)(C) & (D) of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002. Systems to treat higher strength wastewater may be approved on a case by case basis.
4. The system may be used for both new and replacement systems.
5. All effluent from a Bioclere unit shall be discharged to a filtrate disposal system that conforms to the requirements of §1-520 of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002. If the rules are revised during the term of this approval, this approval shall be revised as needed to conform to the revisions.
6. Each application for use shall demonstrate the ability to construct a fully complying replacement system. This replacement system will usually be a sand filter treatment and filtrate disposal system as described in §1-519 of the Wastewater System and Potable Water Supply Rules, effective August 16, 2002.
7. Detailed operating instructions shall be provided in writing to the owner/operator.
8. The Vendor shall have an inventory of replacement parts available locally or available for delivery within 24 hours.
9. The Vendor shall provide a copy of this approval letter to any landowner who is a prospective purchaser of a Bioclere unit prior to the sale of the unit and prior to the filing of any application for a site-specific approval by the Agency for the purchaser's property. The application filed with the Agency shall include the landowner's written acknowledgement of this approval letter. Prior to any sale of the property or completion of a sales agreement to sell the property, a copy of the site-specific permit shall be provided to the prospective purchaser. The owner of record shall notify the Vendor of the sale, and provide contact information for the new owner.
10. The owner of a property where a Bioclere unit has been installed shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency and to the Vendor. Maintenance shall be performed by, or shall be supervised by, a Vermont Registered Professional Engineer or a Licensed Type B Designer, approved by the Vendor or their representative, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the system, the date of the inspection, and any work required to ensure the system operates in compliance with this approval.

Innovative/Alternative System Approval
#2003-02

- The inspection shall be performed in accordance with the Vendor's Operation and Maintenance requirements submitted as part of the Innovative/Alternative System application package. For residential systems, an effluent sample shall be collected twice annually and tested for BOD₅ and TSS. For commercial systems, the sampling and testing shall be done quarterly. The results of all testing shall be submitted to the Agency and to the Vendor, with the annual inspection report.
11. The first inspection shall be completed no later than 3 months after placing the unit in service. The second inspection shall be completed no later than 12 months after placing the unit in service. Subsequent inspections shall be completed at least once per year based on the date when the unit was first placed in service. More frequent inspections or additional testing, required by the Vendor to ensure proper functioning of the system, shall be conducted in accordance with the Vendor's specifications. All reports shall be filed with the appropriate Regional Environmental Office of the Agency, the Vendor and the landowner no later than 30 days after the date of inspection or sampling.
 12. The Vendor shall submit an annual report to the Agency by April 1 of each year containing the following information for the 12 month period ending December 31 of the previous year:
 - A. The number of permitted units installed in Vermont, including those permitted by the Agency and those permitted by Towns under authority of 24 V.S.A. Chapter 102.
 - B. The address of each installation.
 - C. The name of the owner at the time of installation and any known change in ownership.
 - D. All known problems or failures, with a brief summary of the cause and remedial measures taken.
 - E. Copies of reports from an approved laboratory of all effluent quality testing conducted.
 13. This approval is based on information submitted by the Vendor indicating that the specified models will routinely provide effluent with no more than 30 mg/l of BOD₅ and no more than 30 mg/l of TSS.
 14. When a project is subject to the Wastewater System and Potable Water Supply Rules, effective August 16, 2002, site-specific permission for the use of this product is required in the form of a Water Supply – Wastewater Disposal System Permit.

Innovative/Alternative System Approval
#2003-02

15. A site-specific permit for the use of this product may be revoked if the unit fails to function properly or if the property owner fails to have a valid contract for the required maintenance and inspection of the unit. Revocation of the permit will require that the use of the building be discontinued unless another wastewater disposal system is installed based on prior written approval by the Agency.
16. A town that regulates wastewater disposal systems under 24 V.S.A., Chapter 102 and whose ordinance permits, may approve use of a Bioclere unit subject to all conditions in this approval. The town shall ensure that the maintenance contract is in effect and that the required maintenance is performed.
17. This approval is not a representation or guarantee of the effectiveness, efficiency or operation of a Bioclere unit.

Design and Review Conditions

The following conditions will be used by the Department in reviewing permit applications that include a Bioclere unit:

Equipment

- Bioclere Model Numbers 16/12/350, 16/15/600, 22/15/950, 24/24/1600, 24/30/950, 24/30/1600, 30/24, 36/24, and 36/30

Design and Application

- The treatment unit shall be installed in accordance with the approved plans and the manufacturer's recommendations. The designer shall assure that the system will properly function in all seasons.
- The designer must assess the structural needs of the unit for the specific application site and place the requirements on the design plans.
- The designer must determine the type of backfill required and any necessary placement specifications.
- The designer must assess the ventilation path for the particular application and make any necessary provisions to assure proper flow and control of odor emissions.
- The designer shall consult with the Vendor for proper sizing and include in the design a septic tank effluent filter with easy access for inspection and cleaning.
- The designer must assure routine access to the unit as well as the dosing pump, the sludge return pump and the septic tank effluent filter.

Innovative/Alternative System Approval
#2003-02

- The designer must address flotation issues if the SHWT will be above the bottom of any of the tanks.

Installation Inspection

- The treatment unit shall be set up under the instruction and guidance of an installer/inspector trained by the Vendor.
- The treatment unit shall be inspected by a Professional Engineer registered in Vermont as a civil, civil/sanitary, sanitary or environmental engineer or a Licensed Type B Designer, approved by the Vendor, after construction of the unit and installation of the tanks before backfilling, and after backfilling and grading is complete. The inspection shall include checking for an adequate structural foundation to support the unit, checking for levelness of the tanks, and inspecting for damage and proper assembly.
- Before backfilling, the unit and tankage shall be tested for watertightness by filling the unit or tank with water to a point that is above all below grade openings and holding it at a constant level for 24 hours; there shall be no measurable leakage. During the test the entire unit and tanks shall be inspected for visible leaks. Should the unit or tanks fail the test they may be repaired and retested. The testing and repairs shall be conducted under the direction and in the presence of the inspecting engineer or site technician.
- The engineer or site technician shall inspect all piping for proper installation and watertightness before backfilling.

Start-up

- Start-up of the system and initial operational checks shall be conducted by an installer/inspector trained by the Vendor, who shall submit a report to the owner, the Vendor, and to the inspecting engineer or site technician indicating any problems encountered, their resolution, and affirmation that the system is operating as intended.

Operational Maintenance and Inspection

- The owner shall have a valid maintenance contract in force at all times. The minimum length of any contract shall be for a period of two years. A copy of the initial and each succeeding contract shall be submitted to the appropriate Regional Environmental Office of the Agency and to the Vendor. Maintenance shall be performed by, or shall be supervised by, a Vermont Registered Professional Engineer or a Licensed Type B Designer, approved by the Vendor, who shall provide written inspection reports detailing the maintenance performed on the specific system, any problems that have occurred since the previous inspection, any modifications made to the system,

Innovative/Alternative System Approval
#2003-02

the date of the inspection, the results of all testing, and any work required to ensure the system operates in compliance with this approval.

The inspection shall be performed in accordance with the Vendor's Operation and Maintenance Manual submitted as part of the Innovative/Alternative System application package. For residential systems, an effluent sample shall be collected twice annually and tested for BOD₅ and TSS. For commercial systems, the sampling and testing shall be done quarterly. The results of all testing shall be submitted to the Agency and to the Vendor, with the annual inspection report.

- The first inspection shall be completed no later than 3 months after placing the system in service.
- The second inspection shall be completed no later than 12 months after placing the system in service.
- Subsequent inspections shall be completed at least once per year based on the date when the system was first placed in service. More frequent inspections or additional testing, required by the Vendor to ensure proper functioning of the system, shall be conducted in accordance with the Vendor's specifications.
- All reports shall be filed with the appropriate Regional Environmental Office of the Agency, the Vendor, and the landowner no later than 30 days after the date of inspection or sampling.

Permitting

- The permit shall run with the land.
- A copy of the site-specific permit shall be provided to any prospective purchaser prior to the sale.
- Each new owner of the property shall inform the appropriate Regional Environmental Office of the Agency, and the Vendor, within 30 days of the transfer of the property and include the name and mailing address of the new owner.

Effective December 3, 2003

by Roger Thompson, Jr.
Roger Thompson, Jr.
Regional Office Program Manager