



**Vermont Department of Environmental Conservation**  
**Drinking Water and Groundwater Protection Division**  
One National Life Drive - Main 2  
Montpelier, VT 05620-3521  
[www.septic.vermont.gov](http://www.septic.vermont.gov)

[phone] 802-585-4911  
[in-state] 800-823-6500  
[fax] 802-828-1541

*Agency of Natural Resources*

October 12, 2015

Anastasia R. O'Hara  
Sales Coordinator  
Water & Waste Management  
Norwesco, Inc.  
P. O. Box 439  
St. Bonifacius, MN 55375-0439  
And  
Snyder Industries, Inc.  
6940 O Street, Suite 100  
Lincoln, NE 68510

RE: Low Profile Septic Tank Approval.

Dear Ms. O'Hara,

This letter is to add the sister company's name to this approval for septic tanks which had been previously approved on December 16, 2013. The following tanks are the approved models:

1000 Gallon Low Profile Tank  
1250 Gallon Low Profile Tank  
1500 Gallon Low Profile Tank

We reviewed the submitted information with the requirements of Section 1-904, Septic Tanks, and Appendix 3-A of the Vermont Wastewater System and Potable Water Supply Rules, effective dated September 29, 2007. The tanks comply with these standards and can be used in the State of Vermont.

Designers should note that the seasonal high groundwater level should not be higher than the liquid level in the tanks. See the Manufacturer's recommendations for counter buoyancy instructions and other technical information at [www.norwesco.com](http://www.norwesco.com) or [www.snydernet.com](http://www.snydernet.com) (NexGen D2 septic tanks).

If you have any questions, please contact me at (802) 585-4890.

Sincerely,

A handwritten signature in black ink that reads "Mary K. Clark". The signature is fluid and cursive, with the first letters of the first and last names being capitalized and prominent.

Mary K. Clark  
Environmental Analyst,  
Innovative/Alternative (I/A) Program Manager