

Wastewater Management Division  
103 South Main St., The Sewing Building  
Waterbury, Vermont 05671-0405

Phone: (802) 241-3822

Fax: (802) 241-2596

January 23, 2008

David H. Cotton, P.E.  
VP Engineering  
Wastewater Technologies, Inc.  
P.O. Box 868  
Milton, VT 05468


Re: Effluent filters

Dear David,

I reviewed the information you submitted as fact sheets related to FT series of Biotube® Effluent Filters and the PVU series of Universal Biotube® Pump Vaults. The fact sheets are referenced below. In both cases the filters are constructed to prevent passage of solids larger in size than 1/8<sup>th</sup> inch which is the sole requirement related to effluent filters. Either series of filters are acceptable for use for systems regulated under the Wastewater System and Potable Water Supply Rules, effective September 29, 2007.

Please contact me at 241-3027 or at the address/phone number above if you have any questions.

Sincerely,



Roger Thompson, Jr.  
Regional Office Programs Manager

Fact sheets:

NSU-FT-FT-1, Rev. 5.2, © 8/04

NSU-FT-FTS-1, Rev. 3.2, © 9/99

NSU-PVU-1257, Rev. 1.2, © 01/04

