

Wastewater Management Division
103 South Main St., The Sewing Building
Waterbury, Vermont 05671-0405

Phone: (802) 241-3822
Fax: (802) 241-2596

May 23, 2008

Carl Rosen
Urell, Inc.
86 Coolidge Avenue
P.O. Box 321
Watertown, Massachusetts 02471-0321

Re: Zoeller TRU-FLOW® Splitter System


Dear Mr. Rosen,

Based on the documentation that you provided related to the Zoeller Splitter System, P/N 173-0001 I conclude that this product may be used in Vermont as a substitute product in place of the traditional D-box design. The use of the riser, P/N 173-0007 will satisfy the riser to grade requirement. The use of the product must be specified by a licensed designer as part of the application package. The designer must provide the installer of the system with all needed instructions for the installation of the system and must inspect the installation as part of the installation inspection.

I will add your product to our website under the heading: **Products that substitute for traditional methods.** I will include the website address of www.zoeller.com.

Please contact me at 241-3027 or at the address/phone number above if you have any questions.

Sincerely,



Roger Thompson, Jr.
Regional Office Programs Manager

