



# VERMONT

## SPILL BUCKET CONTAINMENT TESTING

Facility ID # \_\_\_\_\_

Test Date: \_\_\_\_\_

1. Tank ID Number				
2. Spill Bucket Size (gallons)				
3. Spill Bucket Type (Single/Double Walled)				
4. Has liquid and debris been removed, and the spill bucket cleaned?	Yes	Yes	Yes	Yes
	No	No	No	No
5. Visual inspection (No cracks, loose parts, or separation of the bucket from the fill pipe)	Pass	Pass	Pass	Pass
	Fail	Fail	Fail	Fail
6. Starting water level (measured from bottom)				
7. Ending water level				
8. Test start time				
9. Test end time				
10. Test period (minimum test time: 1 hour)				
<b>Test Results</b>	Pass	Pass	Pass	Pass
	Fail	Fail	Fail	Fail

### Notes:

**Pass/Fail criteria:** If the water level changes less than 1/8 (0.125) inch, the spill containment passes the integrity test. If the water level changes 1/8 (0.125) inch or greater, the spill containment fails the integrity test.

Proper disposal of test liquids: **Test liquids must be managed and disposed in accordance with the VT Hazardous Waste Rules**

Certification - I hereby certify that I am qualified to test the equipment identified in this document and tested for proper operation in accordance with the manufacturer's requirements.

**Technician Name (Print):** \_\_\_\_\_

**Technician Signature:** \_\_\_\_\_

