

<b>REQUIREMENT</b>	<b>EXISTING Tank</b>	<b>PHASE-IN for Existing</b>	<b>NEW Tanks</b>
Stable Foundation	x		x
Continuous Concrete Foundation		x	x
Fill and Vent Lines Minimum Diameter	x		x
Fill and Vent Lines Metallic Materials	x		x
Fill and Vent Lines Sched 40 Steel or Brass		x	x
Piping and Fuel Lines - Corrosion Protection	x		x
Piping and Fuel Lines - Crushing Protection		x	x
Overfill Vent Alarm	x		x
Shut-off Valve			x
Tank Legs Max Length		x	x
Rust on Tank and Legs, Pitting, Bulging, etc.	x		x
Unused Openings Closed/Plugged	x		x
Fuel Gauge Device			x
Outdoor ASTs - Protection from Ice/Snow Damage		x	x
For Manifolder Tanks - Each Tank is Compliant	x		x
ASTs in Flood Prone Area - Tank Anchoring		x	x