

SOIL TEST PIT LOG

Project: East Street Commercial Plaza

Ground Surface Slope: 0-6%, varies Logged By: Jimmy James, Site Technician

Test Pit #	Depth (inches)	Texture	Consistence or Density	Color	Mottles	Comments
14-01	0-10	Fine sandy loam; little fine gravel.	Friable, subangular blocky	Medium brown		Topsoil, moist, roots
	10-48	Fine to medium sandy loam (with 1" thin layers of silt)	Loose, granular	Tan and Rust		Moist
	48-54	Fine to medium sandy loam.	Loose, granular	Rust	Many, prominent	Moist SHWT = 48"
	54-74	Medium to coarse sand; little fine gravel.	Loose, granular	Grey		Moist to wet GW = 64"
	74-84	Silty clay	Friable to firm	Grey		Wet
	>84	NLTD				

Note:

NLTD - No ledge to depth

NGWTD - No groundwater to depth

SHWT - Seasonal high water table